

イ 簡易水道

市町村名	水道事業名	経営区分	創設時 給水開始 年月	最新認可 年月日	人口			原水 種別	浄水施設		配水池		計画 1日最大 取水量 (m ³ /日)	1日最大給水量 (m ³ /日)		実績 1日平均 給水量 (m ³ /日)
					計画 給水	現在			処理能力 (m ³ /日)	浄水方法	池 数	容 量		計画値	実績値	
						給水 区域内	給水									
那須塩原市	大都富士山	私	S48.9	S48.11.1	300			深		消毒のみ			60	60		
那須塩原市	第3リッチランド	私	S50.3	S50.3.20	320			浅		消毒のみ			48	48		
那須町	平和郷	私	S45.10	H5.12.28	1,400	923	923	浅	350	消毒のみ	1	100	720	350	343	171
那須町	平和台	私	S46.10	H5.12.28	400	533	533	浅	230	消毒のみ	1	100	230	100	127	85
	那珂川水系				2,420	1,456	1,456		580		2	200	1,058	558	470	256
日光市	日光二社一寺	私	T15.6	T14.7.23	700	400	155	伏・自	3,800	緩速ろ過	2	360	4,000	3,800	1,951	1,589
	鬼怒川水系				700	400	155		3,800		2	360	4,000	3,800	1,951	1,589
鹿沼市	ヒルタウンさつき野	組	H4.2	H14.11.7	3,073	2,056	2,056	深	1,500	消毒のみ	3	854	1,480	1,100	765	614
	渡良瀬川水系				3,073	2,056	2,056		1,500		3	854	1,480	1,100	765	614
	合 計				6,193	3,912	3,667		5,880		7	1,414	6,538	5,458	3,186	2,459

水道事業名	水源の種別・実績年間取水量(m ³ /年)								実績年間水量(m ³ /年)							
	ダム	湖水	自流	伏流水	浅井戸	深井戸	浄水 受水	その他	取水量	給水量	有収水量			無収 水量	有効 水量	無効 水量
											合計	生活用	その他			
大都富士山																
第3リッチランド																
平和郷					262,800				262,800	62,429	12,936	12,936		49,493	62,429	
平和台					83,950				83,950	31,010	10,551	10,551		20,459	31,010	
那珂川水系					346,750				346,750	93,439	23,487	23,487		69,952	93,439	
日光二社一寺			400,000	600,000					1,000,000	580,000	95,000	65,000	30,000	400,000	495,000	85,000
鬼怒川水系			400,000	600,000					1,000,000	580,000	95,000	65,000	30,000	400,000	495,000	85,000
ヒルタウンさつき野						231,433			231,433	224,066	221,446	199,735	21,711	1,210	222,656	1,410
渡良瀬川水系						231,433			231,433	224,066	221,446	199,735	21,711	1,210	222,656	1,410
合 計			400,000	600,000	346,750	231,433			1,578,183	897,505	339,933	288,222	51,711	471,162	811,095	86,410

市町村名	事業名	管種	管種別延長(m)／管種別構成比(%)								管路総計	耐震管	法定耐用年数超	
			鋳鉄管	ダクタイル鋳鉄管	鋼管	石綿セメント管	硬質塩化ビニル管	コンクリート管	鉛管	ポリエチレン管				その他
那須塩原市	大都富士山	導水管										0		
		送水管										0		
		配水管										0		
		合計	0	0	0	0	0	0	0	0	0	0		
		構成比												
那須塩原市	第3リッチランド	導水管										0		
		送水管										0		
		配水管										0		
		合計	0	0	0	0	0	0	0	0	0	0		
		構成比												
那須町	平和郷	導水管				10						10		
		送水管				530	1,182					1,712		
		配水管					15,150					15,150		
		合計	0	0	0	540	16,332	0	0	0	0	16,872	未把握	未把握
		構成比	0.0%	0.0%	0.0%	3.2%	96.8%	0.0%	0.0%	0.0%	0.0%	100.0%		
那須町	平和台	導水管					10					10		
		送水管					88					88		
		配水管					6,871					6,871		
		合計	0	0	0	0	6,969	0	0	0	0	6,969	未把握	未把握
		構成比	0.0%	0.0%	0.0%	0.0%	100.0%	0.0%	0.0%	0.0%	0.0%	100.0%		
那珂川水系		導水管	0	0	0	10	10	0	0	0	0	20		
		送水管	0	0	0	530	1,270	0	0	0	0	1,800		
		配水管	0	0	0	0	22,021	0	0	0	0	22,021		
		合計	0	0	0	540	23,301	0	0	0	0	23,841	0	0
		構成比	0.0%	0.0%	0.0%	2.3%	97.7%	0.0%	0.0%	0.0%	0.0%	100.0%	0.0%	0.0%
日光市	日光二社一寺	導水管	400				1,900					2,300		
		送水管	100									100		
		配水管	4,750	950			150			1,550		7,400		
		合計	5,250	950	0	0	2,050	0	0	1,550	0	9,800	2,100	未把握
		構成比	53.6%	9.7%	0.0%	0.0%	20.9%	0.0%	0.0%	15.8%	0.0%	100.0%	21.4%	
鬼怒川水系		導水管	400	0	0	0	1,900	0	0	0	0	2,300		
		送水管	100	0	0	0	0	0	0	0	0	100		
		配水管	4,750	950	0	0	150	0	0	1,550	0	7,400		
		合計	5,250	950	0	0	2,050	0	0	1,550	0	9,800	2,100	0
		構成比	53.6%	9.7%	0.0%	0.0%	20.9%	0.0%	0.0%	15.8%	0.0%	100.0%	21.4%	0.0%
鹿沼市	ヒルタウンさつき野	導水管					783					783		
		送水管										0		
		配水管		907			8,736					9,643		
		合計	0	907	0	0	9,519	0	0	0	0	10,426	未把握	未把握
		構成比	0.0%	8.7%	0.0%	0.0%	91.3%	0.0%	0.0%	0.0%	0.0%	100.0%		
渡良瀬川水系		導水管	0	0	0	0	783	0	0	0	0	783		
		送水管	0	0	0	0	0	0	0	0	0	0		
		配水管	0	907	0	0	8,736	0	0	0	0	9,643		
		合計	0	907	0	0	9,519	0	0	0	0	10,426	0	0
		構成比	0.0%	8.7%	0.0%	0.0%	91.3%	0.0%	0.0%	0.0%	0.0%	100.0%	0.0%	0.0%
簡易水道事業合計		導水管	400	0	0	10	2,693	0	0	0	0	3,103		
		送水管	100	0	0	530	1,270	0	0	0	0	1,900		
		配水管	4,750	1,857	0	0	30,907	0	0	1,550	0	39,064		
		合計	5,250	1,857	0	540	34,870	0	0	1,550	0	44,067	2,100	0
		構成比	11.9%	4.2%	0.0%	1.2%	79.1%	0.0%	0.0%	3.5%	0.0%	100.0%	4.8%	0.0%