

## Tochigi Prefecture Tap Water Test Results (January 13)

Tested on: Purified Tap Water

Unit: Bq/kg

Water System	Water Supplier	Latest Sample Date (M/D)	Radioactive Cesium	
			134	137
			Amount Detected	Amount Detected
Kinugawa River	Utsunomiya City	<u>2022/12/15</u>	Undetected ( < 0.60 )	Undetected ( < 0.60 )
	Nikko City	<u>2022/12/7</u>	Undetected ( < 0.70 )	Undetected ( < 0.50 )
	Moka City	<u>2022/12/6</u>	Undetected ( < 0.67 )	Undetected ( < 0.68 )
	Takanezawa Town	<u>2022/10/10</u>	Undetected ( < 0.69 )	Undetected ( < 0.84 )
	Kinu Waterworks *2	<u>2022/12/8</u>	Undetected ( < 0.74 )	Undetected ( < 0.65 )
Nakagawa River	Yaita City	<u>2022/11/16</u>	Undetected ( < 0.60 )	Undetected ( < 0.60 )
	Nasu-Shiobara City	<u>2022/12/1</u>	Undetected ( < 0.70 )	Undetected ( < 0.80 )
	Shioya Town	<u>2022/12/9</u>	Undetected ( < 0.60 )	Undetected ( < 0.70 )
	Nasu Town	<u>2022/11/21</u>	Undetected ( < 0.90 )	Undetected ( < 0.70 )
	Kita-Nasu Waterworks*3	<u>2022/12/8</u>	Undetected ( < 0.82 )	Undetected ( < 0.68 )
Omoigawa River	Oyama City	<u>2022/12/20</u>	Undetected ( < 0.71 )	Undetected ( < 0.97 )
	Nogi Town	<u>2022/12/7</u>	Undetected ( < 0.54 )	Undetected ( < 0.66 )
Ground-water	Ashikaga City	<u>2022/10/12</u>	Undetected ( < 0.69 )	Undetected ( < 0.60 )
	Tochigi City	<u>2022/12/2</u>	Undetected ( < 1.00 )	Undetected ( < 1.00 )
	Sano City	<u>2022/12/2</u>	Undetected ( < 0.90 )	Undetected ( < 0.90 )
	Kanuma City	<u>2022/12/12</u>	Undetected ( < 0.60 )	Undetected ( < 0.60 )
	Ohtawara City	<u>2022/11/15</u>	Undetected ( < 0.70 )	Undetected ( < 0.70 )
	Sakura City	<u>2022/10/13</u>	Undetected ( < 0.78 )	Undetected ( < 0.75 )
	Nasu-Karasuyama City	<u>2023/1/11</u>	Undetected ( < 0.72 )	Undetected ( < 0.86 )
	Shimotsuke City	<u>2022/12/8</u>	Undetected ( < 0.70 )	Undetected ( < 0.80 )
	Kaminokawa Town	<u>2022/12/1</u>	Undetected ( < 0.30 )	Undetected ( < 0.40 )
	Motegi Town	<u>2022/11/15</u>	Undetected ( < 0.67 )	Undetected ( < 0.65 )
	Mibu Town	<u>2022/10/14</u>	Undetected ( < 1.00 )	Undetected ( < 1.00 )
	Nakagawa Town	<u>2022/12/8</u>	Undetected ( < 0.70 )	Undetected ( < 0.60 )
	Haga Central Waterworks *1	<u>2022/12/5</u>	Undetected ( < 0.81 )	Undetected ( < 0.79 )
Management Target Value (Sum of Cesium 134 and 137)			10	

Underlined portions are reports released today.

\* Some cities and towns have multiple samples, but this table includes the highest values. For more information, please contact the city or town.

\*Lowest detectable limit is written in parentheses.

\*1 Homes in Mashiko Town, Ichikai Town and Haga Town are served by Haga Central Waterworks companies.

\*2 Kinu Waterworks (Business Administration) uses the Kinu Treatment Plant to supply water to a portion of Haga Central Waterworks companies and homes in Utsunomiya, Moka, and Takanezawa. Other homes receive water from the city/town.

\*3 Kita-Nasu Waterworks (Business Administration) uses the Kita-Nasu Treatment Plant to supply water to portions of Nasu-Shiobara and Otawara. The two cities supply water to homes in the area.

### Tap Water Testing at the Source (Separate River Waters)

Unit: Bq/kg

Water System	Sample Source	Latest Sample Date (M/D)	Radioactive Cesium	
			134	137
			Amount Detected	Amount Detected
Nakagawa River	Nasu-Shiobara City	<u>2022/10/13</u>	Undetected ( < 0.64 )	Undetected ( < 0.72 )
	Yaita City (Miyagawa River)	<u>2022/10/13</u>	Undetected ( < 0.63 )	Undetected ( < 0.67 )
Kinugawa River	Takanezawa Town	<u>2022/10/13</u>	Undetected ( < 0.55 )	Undetected ( < 0.77 )
Omoigawa River	Oyama City	<u>2022/10/13</u>	Undetected ( < 0.54 )	Undetected ( < 0.72 )

Underlined portions are reports released today.

\* Tap water source refers to untreated water.

\*Tap water source testing is conducted on sources that are collected at the water's surface. We have surveyed three river basins to represent the prefecture: Nakagawa, Kinugawa and Omoigawa Rivers.

\*Lowest detectable limit is written in parentheses.